



Metro Testing + Engineering

8703 – 109th Street, Fort St. John BC, V1J 7C5
Tel: (250) 261-6615



CERTIFIED TESTING LABORATORY

SIEVE ANALYSIS REPORT

Series 8 16 30 50

TO METRO TESTING



PROJECT NO. NG-30319

CLIENT PEACELAND/SPRINGBUCK
CC METRO TESTING + ENGINEERING
PEACELAND OILFIELD
PEACELAND OILFIELD
Metro Testing & Engineering
METRO TESTING & ENGINEERING
METRO TESTING

ATTN: Hossein El Beqai


PROJECT QUALITY MATERIALS TESTING
MATERIALS TESTING

VARIOUS

CONTRACTOR

SIEVE TEST NO. 324 DATE RECEIVED Sep.07.2024 DATE TESTED Sep.09.2024 DATE SAMPLED Sep.04.2024

SUPPLIER	JULIENNE PIT	SAMPLED BY	CLIENT
SOURCE	STOCKPILE	TESTED BY	RA
SPECIFICATION	MOT 2016 WGB 25MM	TEST METHOD	WASHED
MATERIAL TYPE	12.5 WINTER SAND		ASTM C136 and ASTM C117



GRAVEL SIZES	PERCENT PASSING	GRADATION LIMITS	SAND SIZES AND FINES	PERCENT PASSING	GRADATION LIMITS
3"	75 mm		No. 4	4.75 mm	35.0 - 70.0
2"	50 mm		No. 8	2.36 mm	25.0 - 50.0
1 1/2"	37.5 mm		No. 16	1.18 mm	15.0 - 35.0
1"	25 mm	100.0 - 100.0	No. 30	600 µm	
3/4"	19 mm	80.0 - 100.0	No. 50	300 µm	5.0 - 20.0
1/2"	12.5 mm	100.0	No. 100	150 µm	7.4
3/8"	9.5 mm	50.0 - 85.0	No. 200	75 µm	0.0 - 5.0

MOISTURE CONTENT: 0.7%

Crushed-1 Face 95.0%
COMMENTS

DUSTIN DELISLE